



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354

website www.allaboratory.com

Laboratory Report

Calais Middle/High School
34 Blue Devil Hill Suite 2
Calais, ME 04619

Date Printed: 10/26/2021
Work Order #: 2110-03803
Client Job #: 111
Date Received: 10/22/2021
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:

Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:

Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 10/26/2021
 CLIENT NAME: Calais Middle/High School

Legend	
Lead Above 4 ppb	⬇
Lead Above 15 ppb	⊗

CLIENT ADDRESS: 34 Blue Devil Hill Suite 2
 Calais, ME 04619

METHOD: EPA 200.8
 EPA ACTION LEVEL: 15 ppb
 MAINE GUIDELINE: 4 ppb
 REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 10/22/2021 09:25AM
 ANALYSIS PACKAGE: Maine Schools-Lead
 RECEIPT TEMPERATURE: 17° CELSIUS
 CLIENT JOB #: 111

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2110-03803-001	Kitchen Single Bay Sink (Back Wall)	I	KF	10/20/2021 05:56AM	4.8	ppb		⬇	JLR-NH	10/25/2021 08:06PM
2110-03803-002	Kitchen Three Bay Sink (Back Wall)	I	KF	10/20/2021 05:57AM	3.0	ppb			JLR-NH	10/25/2021 08:09PM
2110-03803-003	Kitchen Ice Machine	I	OT	10/20/2021 06:00AM	<1	ppb			JLR-NH	10/25/2021 08:24PM
2110-03803-004	Business Wing Drinking Fountain Upper	I	DWF	10/20/2021 06:01AM	<1	ppb			JLR-NH	10/25/2021 08:27PM
2110-03803-005	Business Wing Drinking Fountain Lower	I	DWF	10/20/2021 06:02AM	<1	ppb			JLR-NH	10/25/2021 08:31PM
2110-03803-006	Business Wing Bottle Fill Station	I	DWF	10/20/2021 06:03AM	<1	ppb			JLR-NH	10/25/2021 08:34PM
2110-03803-007	GYM Drinking Fountain	I	DWF	10/20/2021 06:04AM	7.1	ppb		⬇	JLR-NH	10/25/2021 08:38PM
2110-03803-008	High School Drinking Fountain Upper	I	DWF	10/20/2021 06:14AM	<1	ppb			JLR-NH	10/25/2021 08:49PM
2110-03803-009	High School Drinking Fountain Lower	I	DWF	10/20/2021 06:14AM	<1	ppb			JLR-NH	10/25/2021 08:53PM
2110-03803-010	High School Bottle Fill Station	I	DWF	10/20/2021 06:15AM	<1	ppb			JLR-NH	10/25/2021 08:56PM
2110-03803-011	Middle School Drinking Fountain Upper	I	DWF	10/20/2021 06:17AM	<1	ppb			JLR-NH	10/25/2021 09:07PM
2110-03803-012	Middle School Drinking Fountain Lower	I	DWF	10/20/2021 06:17AM	<1	ppb			JLR-NH	10/25/2021 09:10PM
2110-03803-013	Middle School Bottle Fill Station	I	DWF	10/20/2021 06:18AM	<1	ppb			JLR-NH	10/25/2021 09:14PM
2110-03803-014	Teacher's Lounge	I	OT	10/20/2021 06:19AM	2.0	ppb			JLR-NH	10/25/2021 09:18PM
2110-03803-015	Kitchen Kettle	I	KF	10/21/2021 06:41AM	14.3	ppb		⬇	JLR-NH	10/25/2021 09:21PM

Rebecca L. Labranche
 Laboratory Director