



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

St Croix Regional Technical Center  
34 Blue Devil Hill Suite 1  
Calais, ME 04619

Date Printed: 10/26/2021  
Work Order #: 2110-03786  
Client Job #: 112  
Date Received: 10/22/2021  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. None
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: Data Qualifier (DQ) Flags: None


### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: None

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 10/26/2021  
 CLIENT NAME: St Croix Regional Technical Center

CLIENT ADDRESS: 34 Blue Devil Hill Suite 1  
 Calais, ME 04619

METHOD: EPA 200.8  
 EPA ACTION LEVEL: 15 ppb  
 MAINE GUIDELINE: 4 ppb  
 REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 10/22/2021 09:25AM  
 ANALYSIS PACKAGE: Maine Schools-Lead  
 RECEIPT TEMPERATURE: 17° CELSIUS  
 CLIENT JOB #: 112

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2110-03786-001	Drinking Water Fountain	I	DWF	10/20/2021 06:07AM	<1	ppb			JLR-NH	10/25/2021 07:55PM
2110-03786-002	Bottle Fill Station	I	DWF	10/20/2021 06:08AM	<1	ppb			JLR-NH	10/25/2021 07:59PM
2110-03786-003	Culinary Kitchen Single bay sink	I	KF	10/20/2021 06:09AM	2.6	ppb			JLR-NH	10/25/2021 08:02PM

Rebecca L. Labranche  
 Laboratory Director